



- ANGLED RESIN FILL TYPICAL @ ALL MEMBRANE TERMINATION POINTS.
- CUT-IN REGLET 1" MIN. DEEP, APPLY APPROVED CAULKING AS REQUIRED.
- PREPARE, LEVEL & PATCH SUBSTRATE AS REQUIRED W/APPROVED LEVELING COMPOUND PRIOR TO APPLICATION OF SMARTFLASH PRIMER & MEMBRANE.
- (2) PLY SMARTFLASH MEMBRANE FLASHING EXTEND TOP PLY 12" MIN. HORIZONTALLY ONTO MODIFIED BITUMEN ROOF MEMBRANE.
- CONTINUOUS BEAD OF POLYURETHANE CAULKING REQUIRED IF GAP BETWEEN EDGE OF MODIFIED MEMBRANE & WALL GREATER THAN 1/16" (TYP.)
- ASSURE FULL CONTACT OF COMPOSITE W/ SUBSTRATE & RESIN SATURATION OF FLEECE.
- CONTINUOUS BOTTOM PLY OF SMARTFLASH MEMBRANE @ WALL TO DECK TRANSITION.
- GRANULATED CAP SHEET OVER MODIFIED BASE PLY HORIZONTALLY TERMINATED & TIGHTLY BUTTED TO WALL.

8" MIN.

2"

30-45°

8" MIN.

4"

4"

DRAWING NO.

CTL-02D

TWO PLY BASE FLASHING W/ CUT-IN REGLET

REVISION
9/19/14

ISSUE DATE
8/1/13

SCALE
N.T.S.

DRAWN BY
CT